



**GOVERNMENT OF THE DISTRICT OF COLUMBIA  
CONSTRUCTION CODES COORDINATING BOARD**  
*c/o DCRA– 1100 4<sup>th</sup> Street SW, Washington, DC 20024*

---

**CODE CHANGE PROPOSAL FORM**

PAGE 1 OF 2

CODE: Plumbing Code

SECTION NO. 1302. 6

SUBCOMMITTEE AMENDMENT NO. PC-M-13-6-13

PROPOSING SUBCOMMITTEE: Mechanical TAG CHAIR: Lourenco PHONE: 202-966-0042 E-mail: al@lourenconsult.com

DATES OF PROPOSAL: 6/19/12

CCCCB PRESENTATION: 6.28.12

CCCCB APPROVAL: 7.3.12

CHECK ONE

☒ *Revise section to read as follows:*

☐ *Delete section and substitute the following:*

☐ *Add new section to read as follows:*

☐ *Delete section without substitution.*

TYPE ALL TEXT IN 12-POINT TIMES NEW ROMAN FONT

~~LINE THROUGH TEXT TO BE DELETED~~ (highlight text, under Format, click font and check strikethrough)

UNDERLINE TEXT TO BE ADDED

Use additional sheets of the form, if necessary.

See next page

Anticipated impact of code change on cost of construction (CHECK ONE)

☐ *Increase*

☐ *Decrease*

☒ *Negligible*

☐ *Unknown*

*Per 1,000 SF single-family dwelling* to

*Per 1,000SF of commercial building* to

**JUSTIFICATION OF CHANGE:**

Please reference one or more of the criteria required

☒ **To address a critical life/safety, health, general welfare need.**

☒ **To address a specific District of Columbia policy or statute**

☐ **For consistency with federal, or with reference to the Metro DC area (MD, VA) codes**

☐ **Address a unique character issue in the District of Columbia**

☐ **Correction of errors and omissions**

☐ **Other (explain)**

To prevent inadvertent drainage from prohibited fixtures to the gray water system, both during initial installation and in future alterations.

**SECTION 1302**  
**SYSTEMS FOR FLUSHING WATER CLOSETS AND URINALS**

*Strike Section 1302.6 of the International Plumbing Code in its entirety and insert new Sections 1302.6 to the Plumbing Code in its place to read as follows:*

**1302.6 Identification.** Distribution piping and reservoirs shall be identified as containing nonpotable water. Gray water collection piping shall be identified so as to preclude drainage pipe connections from prohibited fixtures. Piping identification shall be in accordance with Section 608.8.